



Architectural Series, Fire Protection Cabinet, Ambassador - C1015V10FX2
FE FX2 CABINET, AMBASSADOR, 3/8" FT, VERT DUO, CLR ACR, ALL CRS, ALL WHT, 10 TUB



SPECIFICATIONS:

Tub Material: 24 gauge galvanized steel
Trim Material & Style: 20 gauge CRS, fully recessed 3/8\" square edge
Door Material & Style: 20 gauge CRS, vertical duo
Flange Material: 22 gauge galvanized steel
Glazing: 0.090\" clear acrylic (8-1/2\" x 22-3/4\")
Finish: Powder coat white door and trim, painted white tub
Hinge: Continuous hinge opens door 180 degrees, 20 gauge CRS powder coat white
Hardware: Zinc plated pull handle, roller catch, glass clips & screws
Rough Opening: 12-13/16\" x 26-5/16\" x 6-15/16\"
Fire Rating: UL classified and labeled up to 2 hours in accordance with UL 1479 (ASTM-E814) and CAN/USC-S115.
Insulation: Foil-faced mineral wool
ADA Compliant: Cabinet meets 4\" maximum protrusion, locate handle maximum 48\" above floor
Compatible Extinguisher: Cosmic, Galaxy 2.5 - 10lb, Mercury 2.5 - 5lb, Sentinel 5lb

MODEL # BREAKDOWN:

C — Product Line: Fire protection, cabinet
 — Tub Material: Galvanized
 10 — Tub Size: 10-1/2\" x 24\" x 6\"
 1 — Trim and Door Material: CRS, powder coat finish
 5 — Trim Style: Fully recessed 3/8\" square edge
 V — Door Style: Vertical duo, pull handle, roller catch
 10 — Door Glazing: 0.090\" clear acrylic
 FX2 — Fire Rated
 — Color: All white

REPLACEMENT PARTS:

Tub: TUB-10-5FX2
 Trim: T-1015
 Door: D-101V
 Glazing: G10F10
 Hardware Pack: HPFPUS

MODEL #: C1015V10FX2



JL INDUSTRIES

800-554-6077

sales@activarcpg.com

www.activarcpg.com

9702 Newton Ave S. Bloomington, MN 55431 | Many Locations Nationwide

© 2026 Activar Construction Products Group, Inc.

THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF ACTIVAR CONSTRUCTION PRODUCTS GROUP, INC. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF ACTIVAR CONSTRUCTION PRODUCTS GROUP, INC. IS PROHIBITED.

Distributor:

Contractor:

Date:

Scale: 1:8.25

Quantity:

Pages: 1 OF 1

Project:

Approved By:

Architect:

Drawing #: C1015V10FX2-SUBMITTAL

REV: A 1/6/2026