



AIR LOUVERS
activarcpg.com
800-554-6077

Rain Drip

1. Position the unit on the door frame directly above the opening.
2. Cut to length so it matches the width of the door, extending 2" beyond each side. (Total 4" longer than door width)
3. Secure in place using the supplied screws.
4. Check clearance to confirm the top edge of the door does not strike the drip when opening or closing.



Positive Pressure Tested Gasketing Materials for Fire Doors. Intended for Application to/ with listed steel frames and/or classified steel covered composite, hollow metal type fire doors rated up to 3 hours, wood and plastic covered composite type fire doors rated up to 1-1/2 hours, and wood core type fire doors rated up to 20 minutes. Meets UL10B, UL10C and CAN4-S104-2010 Category J.

17L5 9903