

FIRE EXTINGUISHERS - SENTINEL CARBON DIOXIDE NON-MAGNETIC- A - Portable Handheld

Carbon dioxide is discharged as a white cloud of “snow” which smothers a fire by eliminating oxygen. It is effective for Class B flammable liquids and is electrically non-conductive. Carbon Dioxide is a clean, non-contaminating, odorless gas. Can be used in MRI rooms - MR Conditional to 11.7 Tesla.



CLASS B FIRES

Flammable
Liquids
and Gases



CLASS C FIRES

Energized
Electrical
Equipment

SPECIFICATIONS:

This extinguisher contains liquid carbon dioxide under pressure.

Conforms to Test Standards: CAN/ULC-S503, ANSI/UL154 & CAN/ULC-S508-ANSI/UL711

MR Conditional: This extinguisher has been tested to operate properly and pose no safety hazard in an MRI environment associated with MR systems operating at 11.7 Tesla or less.


Operation: Squeeze the lever, which opens the valve, allowing the carbon dioxide to be forced out. The discharge, which changes into a gas and appears as a smothering cloud of white snow, is then directed to the fire through a funnel-shaped horn. Electrically non-conductive.

Bracket: Non-magnetic J-hook for wall mounting included.

Temperature Range: -22° F (-30° C) to 120° F (49° C)

Construction: Lightweight, high-pressure, aluminum cylinder with O-ring seal and straight thread chrome-plated brass valve. The Sentinel is absolutely rust-free and up to 30% lighter than CO2 units with steel cylinders.

All units meet the current requirements established by the National Fire Protection Association (NFPA) for NFPA10 “Standard for Portable Fire Extinguishers”, and any other applicable NFPA standards. Tested and listed by UL to meet construction and performance standards for this type of extinguisher, and can be used where required by local codes such as OSHA.

Qty.	Model	Type	Nominal Capacity	Shipping Weight	Cylinder Dia.	Overall Height	Overall Width	Shipping Vol	UL Rating 
	Sentinel 5 Non-Magnetic (FS05ANM)	Carbon Dioxide	5 lbs.	14 lbs.	5-1/4"	17-3/4"	8-1/4"	.65 cu.ft.	5B:C

Non-magnetic J Hook wall bracket standard.

Note: NFPA regulations also require extinguishers to be inspected when initially placed in service and all local fire code and tagging requirements must be adhered to. All fire extinguisher sizes are nominal. Contact Customer Service for more information about ordering tagged extinguishers in your area.



9702 Newton Ave S. Bloomington, MN 55431 | Many Locations Across North America

800-554-6077

sales@activarcpg.com

www.activarcpg.com

Distributor:

Contractor:

Date:

Scale: N/A

Project:

Approved By:

Architect:

Item #:

Pages: 1 of 1